



Ref. Certif. No.

SE-104332**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Wenzhou CHT Electric Co., Ltd.
808# Binhai Nine Road, Wenzhou Economic Development Zone,
Wenzhou, Zhejiang, China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Un=240/415V~(1P), 50/60Hz,
In= 1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 45,
50, 55, 63A, B- & C- Type,
Ics= Icn= 6000A, Energy limiting class 3

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

DGB2-63

Additional information (if necessary may also be reported on page 2)

This certificate replaces previously issued certificate ref. No. SE-84843 dated 31 October 2016 for the same model due to updating standard and adding rated current of 45A and 55A.

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

210100096SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Signature:

Leif Mattsson

Date: 24 March, 2021