

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection

Name and address of the applicant

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development
Zone 325025 Wenzhou Zhejiang
China

Name and address of the manufacturer

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development
Zone 325025 Wenzhou Zhejiang
China

Name and address of the factory

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development
Zone 325025 Wenzhou Zhejiang
China

Note: When more than one factory, please report on page 2☐ Additional information on page 2

Ratings and principal characteristics

1P, 1P+N, 2P, 3P, 3P+N, 4P
Ue: 240 / 415 Vac for 1P, 240 Vac for 1P+N, 415 Vac for 2P, 3P, 3P+N and 4P
In: 32, 40, 50, 63, 80, 100, 125 A
C, D type, 50 / 60 Hz, All poles are protected
Ics = 7,5 kA, Icn = Icn1 = 10 kA
The grid distance "a": 50 mm

Trademark (if any)

CHT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DGB7-125

Additional information (if necessary may also be reported on page 2)

Energy limiting class 3 for 32, 40, 50 and 63 A of C type according to
EN 60898-1:2019.

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015, IEC 60898-1:2015/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

3319416.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands



Date: 2022-07-14

Signature: F.S.Strikwerda