

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers without integral overcurrent protection (RCCBs)

Name and address of the applicant

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological development
Zone 325025 Wenzhou Zhejiang
China

Name and address of the manufacturer

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological development
Zone 325025 Wenzhou Zhejiang
China

Name and address of the factory

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological development
Zone 325025 Wenzhou Zhejiang
China

Note: When more than one factory, please report on page 2

☐ Additional information on page 2

Ratings and principal characteristics

1P+N, 3P+N
Ue: 240 Vac for 1P+N, 415 Vac for 3P+N
In: 40, 63 A, 50 / 60 Hz
IΔn: 0,03, 0,1, 0,3 A for general type and type G (A, AC, A-G, AC-G),
0,1, 0,3 A for type S (A-S, AC-S)
Type A and AC, type S and type G
Without time delay for general type, with time delay for type S and type G
Inc = IΔc = 10 kA, Im = IΔm = 1 kA, the grid distance "a" = 50 mm

Trademark (if any)

CHT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DGL2-63

Additional information (if necessary may also be reported on page 2)

Ambient air temperature: -25 °C to 40 °C (-25 °C was tested according to EN 61008-1).

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010, IEC 61008-1:2010/AMD1:2012, IEC 61008-1:2010/AMD2:2013, IEC 61008-2-1:1990

As shown in the Test Report Ref. No. which forms part of this Certificate

3319425.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands


Date: 2022-06-08

Signature: H.L. Schendstok

