

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air Circuit-Breaker

Name and address of the applicant

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development
Zone 325025 Wenzhou Zhejiang,
China

Name and address of the manufacturer

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development
Zone 325025 Wenzhou Zhejiang,
China

Name and address of the factory

Note: When more than one factory, please report on page 2

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development
Zone 325025 Wenzhou Zhejiang,
China

☐ Additional information on page 2

Ratings and principal characteristics

Ue: 400 / 690 Vac, Ui: 1000 V, Uimp: 12 kV,
3P or 4P (N pole with overcurrent protection)
In: 200 A, 250 A, 400 A, 630 A, 800 A, 1000 A, 1250 A, 1600 A
Ics = Icu: 42 kA at 400 Vac, 25 kA at 690 Vac
Icw: 42 kA / 1 s at 400 Vac, 25 kA / 1 s at 690 Vac
See annex for further ratings

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DGW3-1600

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016, IEC 60947-2:2016/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

3319453.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands



Date: 2023-08-08

Signature: F.S.Strikwerda