

# ATTESTATION OF CONFORMITY

Issued to: Wenzhou CHT Electric Co., Ltd.  
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone  
325025 Wenzhou Zhejiang, China

For the product: Circuit-breakers for overcurrent protection

Trade name: CHT

Type/Model: DGB7-125

Ratings: 1P, 1P+N, 2P, 3P, 3P+N, 4P  
Ue: 240 / 415 Vac for 1P, 240 Vac for 1P+N, 415 Vac for 2P, 3P, 3P+N and 4P  
In: 32, 40, 50, 63, 80, 100, 125 A, C, D type, 50 / 60 Hz, all poles are protected  
Ics = 7,5 kA, Icn = Icn1 = 10 kA, energy limiting class 3 for 32, 40, 50 and 63 A of C type, the grid distance "a": 50 mm

Manufactured by: Wenzhou CHT Electric Co., Ltd.  
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone  
325025 Wenzhou Zhejiang, China

Subject: Type Test

Requirements: EN 60898-1:2019, IEC 60898-1:2015, IEC 60898-1:2015/A1:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report 3319416.50 issued on 2022-07-05.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou Zhejiang, 20 July 2022

Number: 3319416.01A

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

