

ATTESTATION OF CONFORMITY

Issued to: Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone
325025 Wenzhou Zhejiang, China

For the product: Moulded-Case Circuit-Breaker

Trade name: CHT

Type/Model: DGM2-400, DGM2-630

Ratings: Ue: 415 Vac, 50 / 60 Hz
Ui: 800 V, Uimp: 8 kV,
In: 250 A, 315 A, 350 A, 400 A, 500 A, 630 A
3P and 4P (N pole without overcurrent protection)
See annex for further ratings

Manufactured by: Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone
325025 Wenzhou Zhejiang, China

Subject: Type test

Requirements: EN 60947-2:2017, EN 60947-2:2017/A1:2020, IEC 60947-2:2016,
IEC 60947-2:2016/A1:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no. 3319433.50 issued on 2022-11-08.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 06 December 2022 Number: 3319433.01A

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

