

Certificate of Conformity/Approval

Certificate No.: SAA-231106-EA

Certificate Holder: Wenzhou CHT Electric Co., Ltd.

808#, Binhai Nine Road, Wenzhou Economic

Development Zone, Wenzhou,

Zhejiang 325025 P.R. China

Regulatory Definition: Residual Current Device

Product Description: Residual Current Operated Circuit-breaker

(with Integral Overcurrent Protection for Household and

Similar Uses, RCBO)

Standard/s: AS/NZS 61009.1:2015

Condition/s: Type AC RCDs are not approved under the NSW Recognised

External Approval Scheme.

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)

and

SAA-231106-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 2 August 2023

Expiry Date: 2 August 2028

For and on Behalf of SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein. For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ

www.jas-anz.org/register



Issued: 02-11-23 231106 Correction Page 1 of 2



Certificate of Conformity/Approval

Model **Trade Name** Rating/Marking DGB1LE-40 CHT Un: 240V(230V)~ 1P+N 50/60Hz, with switched neutral pole In: 6, 10, 16, 20, 25, 32, 40A, Type B-, C- & D-IΔn: 30mA, Type A and Type AC IΔm: 2000A Icn=Ics: 4500A DGB1LE-40H CHT Un: 240V(230V)~ 1P+N 50/60Hz, with switched neutral pole In: 6, 10, 16, 20, 25, 32, 40A, Type B-, C- & D-IΔn: 30mA, Type A and Type AC IΔm: 2000A Icn=Ics: 6000A

For and on Behalf of SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein. For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ

www.jas-anz.org/register



Issued: 02-11-23 231106 Correction Page 2 of 2