

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Type B RCCB
Name and address of the applicant	Wenzhou CHT Electric Co.,Ltd. No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone 325025 Wenzhou Zhejiang China
Name and address of the manufacturer	Wenzhou CHT Electric Co.,Ltd. No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone 325025 Wenzhou Zhejiang China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Wenzhou CHT Electric Co.,Ltd. No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone 325025 Wenzhou Zhejiang China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	1P+N, 3P+N Ue: 240 Vac for 1P+N, 415 Vac for 3P+N In: 25, 40, 63 A, 50 / 60 Hz, I Δ n: 0,03, 0,3 A Type B (Including type A and AC), without time-delay Inc = I Δ c = 10 kA, Im = I Δ m = 1 kA The grid distance "a": 50 mm
Trademark (if any)	CHT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	DGL2-63B
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 Ambient air temperature: - 25 °C ... + 40 °C (-25°C was tested according to EN 62423 / EN 61008-1).
A sample of the product was tested and found to be in conformity with	IEC 61008-1:2010, IEC 61008-1:2010/AMD1:2012, IEC 61008-1:2010/AMD2:2013, IEC 61008-2-1:1990, IEC 62423:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	3319427.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands