

CERTIFICATE

Issued to:

Applicant:

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic &
Technological Development Zone
325025 Wenzhou Zhejiang, China

Licensee:

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic &
Technological Development Zone
325025 Wenzhou Zhejiang, China

Product : Socket-outlet
Trade name(s) : CHT
Type(s)/model(s) : DG20

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019, NEN-IEC 60884-1:2019/A2:2019 and NEN 1020:2019
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6059280


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 15 September 2021 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 31-120355

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



K Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Socket-outlet
Trade name(s)	: CHT
Type(s)/model(s)	: DG20
Rated voltage	: 250 V~
Rated current	: 16A
IP degree	: IP20
Earthing	: With side earthing-contacts
Design	: with shutter, appliance type
Standard sheet	: III of NEN 1020
Type of terminals	: Screw-type
Description	: Body of thermoplastic material

TESTS**Test requirements**

NEN-IEC 60884-1:2019
NEN-IEC 60884-1:2019/A1:2019
NEN-IEC 60884-1:2019/A2:2019
NEN 1020:2019

Test result

The test results are laid down in DEKRA test file 610710100.

Additional information

The list of components is laid down in test report 6107101.50.

Conclusion

The examination proved that all requirements were met.

Factory location

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone
325025 Wenzhou Zhejiang, China