

CERTIFICATE

Issued to:

Applicant:

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic &
Technological Development Zone
325025 Wenzhou Zhejiang, China

Licensee:

Wenzhou CHT Electric Co.,Ltd.
No.808, Ninth Binhai Road, Wenzhou Economic &
Technological Development Zone
325025 Wenzhou Zhejiang, China

Product : Air Circuit-Breaker
Trade name(s) : CHT
Type(s)/model(s) : DGW3-4000

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to EN 60947-2:2017, EN 60947-2:2017/A1:2020, IEC 60947-2:2016 and IEC 60947-2:2016/AMD1:2019
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6059280


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 14 September 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-130354

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.L. Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Air Circuit-Breaker
Trade name(s)	: CHT
Type(s)/model(s)	: DGW3-4000
Number of poles	: 3P or 4P (N pole with overcurrent protection)
Rated operational voltage (U _e)	: 400 / 690 Vac
Rated insulation voltage (U _i)	: 1000 V for main circuit 500 V for control circuit
Rated impulse withstand voltage (U _{imp})	: 12 kV for main circuit 4 kV for control circuit
Rated frequency	: 50 / 60 Hz
Rated current (I _n)	: 2000 A, 2500 A, 2900 A, 3200 A, 3600 A, 3900 A, 4000 A
Conventional thermal current (I _{th})	: Equal to I _n
Current rating for four-pole circuit-breakers	: 50% I _n or 100% I _n
Rated service short-circuit breaking capacity (I _{cs})	: 100% I _{cu}
Rated ultimate short-circuit breaking capacity (I _{cu})	: 80 kA at 400 Vac, 50 kA at 690 Vac
Rated short-time withstand current (I _{cw})	: 80 kA / 1 s at 400 Vac, 50 kA / 1 s at 690 Vac
Individual pole short-circuit (I _{tr})	: 50 kA at 400 Vac
Suitable for isolation	: Suitable
Selectivity category	: B
Safety distance (screen-circuit breaker)	: All sides: 0 mm
Reference temperature	: Independent
Ambient temperature	: - 5 °C to 40 °C
Method of mounting	: Withdrawable or fixed
EMC Environment	: A
Tightening torque for terminals	: M12 / 95 Nm
Line/load terminal	: Immaterial
Connection	: Minimum cross-sectional area of conductor: Copper busbar, (100 x 5) mm ² x 3 Maximum cross-sectional area of conductor: Copper busbar, (100 x 10) mm ² x 5
Inverse time delay release	: I _r : (0,4 - 1,0) x I _n + OFF, step 1 A
Time setting of the inverse time delay release	: t _r : 15 s - 480 s, with tolerance of ± 10% (at 1,5 I _r) tripping time at 2 I _r : 7,60 s - 9,28 s (t _r = 15 s) 243 s - 297 s (t _r = 480 s)
Short time delay release	: I _{sd} : (1,5 - 15) x I _r , OFF, step 1 A
Time setting of the short time delay release	: t _{sd} : I ² t off, 0,1 s - 1 s, step 0,1 s, with tolerance of ± 15% non-tripping duration: t _{sd} of - 15%
Instantaneous release	: I _i : (2 - 15) x I _n , OFF, step 1 A
Ground fault release	: I _g : (0,2 - 1) x I _n , OFF, step 1 A, t _g : I ² t off, 0,1 s - 1,0 s, step 0,1 s, with tolerance of ± 15%
Shunt release	: AC 220 / 230 V, AC 380 / 480 V, 50/60 Hz DC 110 V, DC 220 V
Under-voltage release	: AC 220 / 230 V, AC 380 / 480 V, 50/60 Hz
Closing release	: AC 220 / 230 V, AC 380 / 480 V, 50/60 Hz DC 110 V, DC 220 V
Stored energy motor	: AC 220 / 230 V, AC 380 / 480 V, 50/60 Hz DC 110 V, DC 220 V

TESTS**Test requirements**

EN 60947-2:2017

EN 60947-2:2017/A1:2020

IEC 60947-2:2016

IEC 60947-2:2016/AMD1:2019

Test result

The test results are laid down in DEKRA test file 331945700.

Additional information

Nomenclature breakdown:

DGW3-4000/4

a b c

a = Model name: DGW3

b = Frame size: 4000

c = Number poles: "4" means 4 poles, "3" means 3 poles

The referred test report is 3319457.50.

Conclusion

The examination proved that all requirements were met.

Factory location

Wenzhou CHT Electric Co.,Ltd.

No.808, Ninth Binhai Road, Wenzhou Economic & Technological Development Zone

325025 Wenzhou Zhejiang, China